

April 8, 2026

CDFL ARCHITECTS + ENGINEERS PA
3221 OLD CANTON ROAD, SUITE 200
JACKSON, MISSISSIPPI 39216

ADDENDUM NUMBER ONE (#1)
DSU BASEBALL – SOFTBALL LIGHTING UPGRADES
DELTA STATE UNIVERSITY
CLEVELAND, MS
CDFL #25.061

Plan Holders:

The following changes and clarifications are hereby made a part of and take precedence over conflicting sections of the Drawings and Specifications.



Engineer

GENERAL INFORMATION:

- 1.1 A Prebid Conference was held on April 2, 2026 at 10:00 AM at Delta State University Facilities Conference Room. Attached are the minutes of the meeting, along with the sign-in sheet.

END OF ADDENDUM NUMBER ONE (#1)

PREBID MEETING AGENDA

project: **DSU Baseball - Softball Lighting Upgrades
CDFL 25-061**

regarding: **Pre-Bid Conference**

mtg. date: **04/02/2026, 10:00 AM**

location: **Delta State University Facilities Conference Room**

PARTICIPANTS

CDFL: Andrew Campbell, PE
Matthew Buchanan, AIA

DSU: Cecil Barnett
Forrest Upchurch

Contractors: Andrew Kurtz (MUSCO)
Gerry Logan (MUSCO)
Chris Andrews (Robinson Electric)

minutes by: Andrew Campbell/Matthew Buchanan

ITEMS COVERED FROM MEETING

1. Introductions were made for CDFL design team and DSU staff.
2. Overview of project goals and schedule.
3. Bid date and deadline for questions from Contractors.

Additional Information Provided:

Alternates:

1. Add RGB lighting for fields. Alternates shall include required infrastructure.
2. Increase light levels on the softball field.
3. Add RGBU lighting for poles. Alternates shall include required infrastructure.

Scope of Work Clarifications:

- Intent is to reuse existing infrastructure where feasible.
- Provide one conduit per pole. Conduit size to be determined.
- Contractor shall be responsible for any cutting and patching of pavement. Patching shall match adjacent pavement in material and color, joint to joint.
- Contractor shall be responsible for replacing sod where trenching or equipment damage occurs.
- Light poles shall be accessed from the outfield only and not from the playing field.
- DSU will provide additional access to the left field area of the baseball stadium.
- Contractor shall be responsible for coordinating any necessary utility locates with DSU.

Schedule and Bid Information:

- Construction duration is 180 days from Notice to Proceed.
- Liquidated damages shall be \$500 per day.
- Bid Date: April 14 at 2:00 PM at Kent Wyatt Hall.
- Final questions due April 7 by 5:00 PM.
- Final Addendum to be released by 5:00 PM on April 9, 2026.

END OF DOCUMENT

DSU Baseball/Softball Field Lighting

Pre Bid Meeting 04/02/2026

<u>Name</u>	<u>Company</u>	<u>Email</u>
Andrew Campbell	CDFL	acampbell@cdf1.com
ANDREW KURTZ	MUSCO	ANDREW.KURTZ@MUSCO.COM
Gerry Logan	Musco	gerry.logan@musco.com
Chris Andrews	Robinson Electric	chris@robinson-electric.biz
Matthew Buchanan	CDFL	mbuchanan@cdf1.com
Forrest Upchurch	DSU	fupchurch@deltastate.edu
Cecil Barnett	DSU	cbarnett@deltastate.edu